

**Appendix D:
National Pollutant Discharge Elimination System
Noncompliance Summaries for 2019**

Appendix

D. National Pollutant Discharge Elimination System Noncompliance Summaries for 2019

D.1 Y-12 National Security Complex

The Y-12 National Security Complex was in full compliance with the National Pollutant Discharge Elimination System (NPDES) permit in 2019. Adequate data points were obtained from sampling required by the NPDES permit. Compliance with permit discharge limits for 2019 was 100 percent.

D.2 East Tennessee Technology Park

The East Tennessee Technology Park program was 100 percent compliant with the numerical permit limits during 2019. The current ETP NPDES permit was effective on February 1, 2015 and will remain in effect until March 31, 2020.

D.3 Oak Ridge National Laboratory

In 2019, compliance with the Oak Ridge National Laboratory NPDES permit was determined by 1,800 laboratory analyses and field measurements. The NPDES permit limit compliance rate for all discharge points for 2019 was greater than 99 percent. At ORNL there were one concentration and one loading limit exceedance and two nonnumeric permit noncompliances: a total suspended solids sample and an oil and grease sample were not collected during the required quarterly reporting period.