

**Table 2.2. ORR UST status, 1995**

	<b>Y-12 Plant</b>	<b>ORNL</b>	<b>K-25 Site</b>
Active/in service	4	10	5
Closed	40	42	12
Hazardous substance	3 <sup>a</sup>	0	5 <sup>b</sup>
Upgraded	0	3	0
Known or suspected sites	0	0	16
Total	47	55	38

<sup>a</sup>Two USTs are deferred because they are regulated by the Atomic Energy Act of 1954. The third is a permanently closed methanol UST.

<sup>b</sup>Four USTs, one of which has been closed, were used to store natural gas odorant and are regulated under the Pipeline Safety Act. The fifth UST, designed as a spill-overflow tank, has never been placed into service.